

BOILER & PRESSURE VESSEL SAFETY RULES & REGULATIONS



OFFICE OF THE STATE FIRE MARSHAL
DIVISION OF BOILER & PRESSURE VESSEL SAFETY
 1035 Stevenson Drive
 Springfield IL 62703-4259
 (217) 782-2696
 FAX: (217) 785-4184

Operational and Maintenance Log Hot Water Heating Boilers	Building: _____ Address: _____	Month: _____	Year: _____																												
Person(s) to be Notified in Emergency (Name and Telephone No.)		Fuel Type: _____																													
		Illinois No.: _____																													
CHECKS (Enter Date)																															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
(1) Record Pressure																															
(2) Record Boiler Water Temp																															
(3) Record Flue Gas Temp.																															
CHECKS (Enter Date)																															
	WEEK 1					WEEK 2					WEEK 3					WEEK 4															
(1) Observe Flame Condition																															
(2) Observe Circulating Pumps																															
CHECKS (Enter Date)																															
(1) Manual Lift Safety Valve																															
	(A) Flame Detection Devices										(F) Refractory																				
	(B) Limit Controls										(G) Stop Valves																				
(2) Review Condition of	(C) Operating Controls										(H) Check Valves																				
or Test Each Item	(D) Floor Drains										(I) Drain Valves																				
	(E) Fuel Piping										(J) Linkages																				
(3) Observe Gage Glass on Expansion Tank																															
(4) Combustion Air Adequate/Unobstructed																															
General Comments:																															