



Elevator Research & Manufacturing Corp.

www.elevatorresearch.com

NOVEMBER 15, 2005

TO: WHOM IT MAY CONCERN

RE: ERM DOOR LOCKS

CATASTROPHIC FAILURE POSSIBLE

Please be advised that the ERM door locks were recalled over 15 years ago. If allowed to continue to operate, these units may develop a condition which is extremely **dangerous** and cause serious **liability issues** for the owners of the elevator and the elevator companies maintaining any elevators with ERM door locks.

Our strong recommendation is that any elevator found operating with ERM door locks should be **shut down** immediately and should **NOT** be allowed to run until the door locks are replaced. ERM will not accept responsibility for any problems / accidents that may occur as a result of continuing to run the elevator with these obsolete door locks.

Sincerely,

Clive Mann
General Manager
Elevator Research and Mfg. Corp
Phone (213) 746-1914 Fax (213) 749-1355