



Elevator Research & Manufacturing Corp.

October 4, 2005

Re: ERM Door Operator


To Whom It May Concern:

Please be advised that the old ERM Door Operator has been out of production for the last 20 years. No spare parts are available for this unit as it was recalled at that time.

We consider continued use of this unit to be a safety concern and liability issue. Instructions were issued to our customers 20 years ago to replace this unit and we recommend that you shut down the car immediately and change out the Door Operator.

We trust this information will be useful in making the appropriate decision.

Yours Very Truly,



Clive Mann
General Manager