



*Office of the State Fire Marshal*

---

**M E M O R A N D U M**

**TO: Elevator Companies**

**FROM: Robert Capuani**

**DATE: January 10, 2008**

**RE: BOARD DECISION - LED FOR PHASE 1**

At the January 10, 2008 Board meeting the Board interpreted and accepted an LED as an illuminated visual signal. ASME A17.1-2004 (2.27.3.1.5) states that all Fire Recall Switches be provided with an illuminated visual signal to indicate Phase 1 Emergency Recall operation.

RC